


## CERTIFICATE

The Classrooms of Little Flower Convent School, Hanumangarh Jn. are well ventilated. There is facility for drinking water. There is provision for separate toilets for boy's and girl's and general cleanliness is good.

  
चिकित्सा अधिकारी  
राजकीय चिकित्सालय कैनाल कॉलोनी  
हनुमानगढ़ जखान



# Public Health Engineering Department

District Laboratory, Hanumangarh

## BACTERIOLOGICAL EXAMINATION REPORT

No. / JC / Lab / HMH / BR / 20-206 / 888

Dated ... 31.10.25

To,

The MANAGER

HANUMANGARH

Little Flower convent school

Distt. ....

Hanumangarh

Tehsil HMH

Reference : Your Letter No. 757

: Date of Receipt 27.10.25

Sample Collected by .....

Sample No.	Date & Time of Collection	Date of Examination	Residual Chlorine in PPM	Particulars of Sample	Coliform organism MPN Per 100 ml
1942	<u>28/10/25</u> <u>2.20 pm</u>	<u>28/10/25</u>	<u>0</u>	<u>Tap Little Flower convent school</u>	<u>254</u>

Remark :

[Signature]  
JUNIOR CHEMIST  
PHED LAB, HANUMANGARH

Dated.....

No. / JC / Lab / HMH / BR / 20 -20  
Copy submitted to :-

JUNIOR CHEMIST



Public Health Engineering Department, Rajasthan  
Distict Laboratory, Hanumangarh

Report of the Chemical Examination of Water

888  
31/10/25

Date : 31/10/2025

To  
Manager  
little flower convent school,  
Hanumangarh


District : HANUMANGARH  
Town : Hanumangarh (M)

Reference No : 2281, Dated : 27/10/2025  
Receipt Date : 27/10/2025  
Date of Collection : 27/10/2025  
Date of Exam : 27/10/2025

Sample No. : 757  
Source : Tap  
Location : little flower school

Test Name	Desirable Limit	Permissible Limit in absence of Alternate	Test Result
pH	6.5 to 8.5	No relaxation	7.50
Turbidity(NTU)	1	5	Clear
Colour	5	15	Colourless
Odour	Agreeable	Agreeable	Smell less
Temperature	---	---	25
Total Alkalinity	200	600	70
Total Hardness (as CaCO <sub>3</sub> )	200	600	90
Calcium (as Ca)	75	200	20
Magnesium (as Mg)	30	100	9.76
Chloride(as Cl)	250	1000	20
Sulphate(as SO <sub>4</sub> )	200	400	---
Nitrate as(NO <sub>3</sub> )	45	45	01
Fluoride	1.0	1.5	0.20
Total Dissolved Solids	500	2000	200
Iron	1.0	No Relaxation	---
Residual Chlorine	0.2	1.0	0

Remark:  
No.Lab./Tech.(chem)/2025-26/757

  
PHED Laboratory, Hanumangarh