



# Public Health Engineering Department

District Laboratory, Hanumangarh

## BACTERIOLOGICAL EXAMINATION REPORT

No. / JC / Lab / HMH / BR / 20-20 / 898

Dated ... 21/10/25

To,

The MANAGER

HANUMANGARH

Little Flower Convent School

Distt. ....

Hanumangarh


Tehsil H.M.H.

Reference : Your Letter No. 757

: Date of Receipt 27/10/25

Sample Collected by .....

Sample No.	Date & Time of Collection	Date of Examination	Residual Chlorine in PPM	Particulars of Sample	Coliform organism MPN Per 100 ml
1942	28/10/25 2:00 pm	28/10/25	0	Tap Little Flower Convent School	254

  
**MANAGER**  
 LITTLE FLOWER CONVENT SCHOOL  
 HANUMANGARH JN.-335512

Remark :

  
 Principal

Little Flower Convent School  
 Hanumangarh Jn.-335512

  
**JUNIOR CHEMIST**  
 PHED LAB, HANUMANGARH

No. / JC / Lab / HMH / BR / 20 -20

Dated.....

Copy submitted to :-



Public Health Engineering Department, Rajasthan  
 Distict Laboratory, Hanumangarh

Report of the Chemical Examination of Water

899  
 31/10/25

Date : 31/10/2025

To  
 Manager  
 little flower convent school,  
 Hanumangarh

District : HANUMANGARH  
 Town : Hanumangarh (M)

Refrence No : 2281, Dated : 27/10/2025  
 Receipt Date : 27/10/2025  
 Date of Collection : 27/10/2025  
 Date of Exam : 27/10/2025

Sample No. : 757  
 Source : Tap  
 Location : little flower school

Test Name	Desirable Limit	Permissible Limit in absence of Alternate	Test Result
pH	6.5 to 8.5	No relaxation	7.50
Turbidity(NTU)	1	5	Clear
Colour	5	15	Colourless
Odour	Agreeable	Agreeable	Smell'less
Temperature	---	---	25
Total Alkalinity	200	600	70
Total Hardness (as CaCO3)	200	600	90
Calcium (as Ca)	75	200	20
Magnesium (as Mg)	30	100	9.76
Chloride(as Cl)	250	1000	20
Sulphate(as SO4)	200	400	---
Nitrate as(NO3)	45	45	01
Fluoride	1.0	1.5	0.20
Total Dissolved Solids	500	2000	200
Iron	1.0	No Relaxation	---
Residual Chlorine	0.2	1.0	0

Remark:  
 No.Lab./Tech.(chem)/2025-26/757

*[Signature]*

Principal

Little Flower Convent School  
 Hanumangarh Jn.-335512

*[Signature]*

PHEC Laboratory, Hanumangarh

*[Signature]*  
 MANAGER

LITTLE FLOWER CONVENT SCHOOL  
 HANUMANGARH JN.-335512


## CERTIFICATE

The Classrooms of Little Flower Convent School, Hanumangarh, Jn. are well ventilated. There is facility for drinking water. There is provision for separate toilets for boy's and girl's and general cleanliness is good.



Principal

Little Flower Convent School  
Hanumangarh Jn.-335512



डी.ओ. अधिकारी  
राजकीय विद्यालय कैनाल कॉलोनी  
हनुमानगढ़ जखान



MANAGER


LITTLE FLOWER CONVENT SCHOOL  
HANUMANGARH JN.-335512

# CERTIFICATE

This is certified that I gave a regular visit to Little Flower Convent School, Hanumangarh Jn. For the medical check-up of the students. Whenever the authority required for medical check-up.

  
Principal  
Little Flower Convent School  
Hanumangarh Jn.-335512

  
MANAGER  
LITTLE FLOWER CONVENT SCHOOL  
HANUMANGARH JN.-335512

  
Principal  
Little Flower Convent School  
Hanumangarh Jn.-335512